

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Socket-outlet for fixed-electrical installations

Name and address of the applicant

**LEGRAND FRANCE**  
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY  
87045 LIMOGES CEDEX  
FRANCE

Name and address of the manufacturer

**LEGRAND FRANCE**  
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY  
87045 LIMOGES CEDEX  
FRANCE

Name and address of the factory

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

CTF3

Model / Type Ref.

Series : PLEXO  
References : See Annex

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC 585402E/A2 dated 27/02/2012. update further to the evolution of the standard(s), update the list of product references

 Additional Information on page 2


A sample of the product was tested and found to be in conformity with

IEC 60884-1:2002(ed.3) +A1:2006 +A2:2013

As shown in the Test Report Ref. No. which forms part of this Certificate

169738-758052A, 169738-758052B, 93022-585393,  
60051320-552098, 109578-618866, 75250-563301,  
SMT/AP08/H00155.1.1, SMT/AP08/H00155.1.3,  
SMT/AP08/H00155.2.1, SMT/AP08/H00155.2.3

This CB Test Certificate is issued by the National Certification Body

LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)

Date: 07/06/2021

Signature: **Julien Gauthier**  
Certification Officer

## ANNEX

**Name and address of the factories:****LEGRAND FRANCE**

128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY  
87045 LIMOGES CEDEX  
FRANCE

**LEGRAND MAGYARORSZAG VILLAMOSSAGI RENDSZEREK ZRT**

IPARTELEPI UT 14 PF 10  
6600 SZENTES  
HUNGARY

**ERP ELBROMPLAST**

Strada Siemens nr.3  
300704 TIMISOARA  
ROMANIA

**LEGRAND FRANCE**

DIVISION INDUSTRIE, ZI DES COUTURES, 519 RUE JULES FERRY  
02120 GUISE  
FRANCE

**LEGRAND FRANCE**

6, rue Paul Nouel  
76770 MALAUNAY  
FRANCE



LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)

Date: 07/06/2021



LABORATOIRE CENTRAL DES  
INDUSTRIES ELECTRIQUES  
S.A.S au capital de 15.745.984 €  
RCS Nanterre B 408 363 174  
33 avenue du Général Leclerc  
F - 92266 FONTENAY AUX ROSES

Signature:  **Julien Gauthier**  
Certification Officer

## ANNEX

## Screwless terminals

Type references	References						Designation
	Composable			Complete product			
	Grey	White	Artic white	Grey	White	Artic white	
TFA	0 695 51	0 696 21	0 707 21	0 697 31			2P+E
TFA	0 695 55						2P+E automatic opening of lid
TFA2H	0 695 62	0 696 42					2P+T two gang horizontal, pre-wired
TFA2V	0 695 63	0 696 43					2P+E two gang vertical, pre-wired
TFA3H	0 695 64	0 696 44					2P+E three gang horizontal, pre-wired
TFA2H				0 697 49			Garden piquet

## Screw-type terminals

Type references	References						Designation
	Composable			Complete product			
	Grey	White	Artic white	Grey	White	Artic white	
TFV	0 695 52	0 696 22					2P+E
TFV2H	0 695 65						2P+E two gang horizontal, pre-wired
	0 695 53	0 696 23					2P+E tamperproof

Standard Sheet	V / I (CEE 7)
Rated current (A)	16A
Rated voltage (V)	250V
Degree of protection	IP55
Provision for earthing	With earthing contact
Method of connecting the cable	Rewirable
Type of terminals	Screw-type - Screwless type (rigid and flexible)
Degree of protection against electric shock	Increased protection
Existence of shutters	With shutters
Method of application - mounting	Surface -type
Method of installation:	Design A



LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)



LABORATOIRE CENTRAL DES  
INDUSTRIES ELECTRIQUES  
S.A.S au capital de 15.745.984 €  
RCS Nanterre B 408 363 174  
33 avenue du Général Leclerc  
F - 92266 FONTENAY AUX ROSES

Signature:   
Julien Gauthier  
Certification Officer

Date: 07/06/2021


## ANNEX (End)

## Box

References			Designation
Grey	White	Artic white	
0 696 51	0 696 89	0 707 41	1 gang with cable gland (1 entry – 1 exit)
0 696 55			1 gang with cable gland (1 entry – 2 exits)
0 696 61	0 696 91	0 707 43	2 gang vertical with cable gland
0 696 79			3 gang vertical with cable gland
0 696 72	0 696 90	0 707 42	2 gang horizontal with cable gland
0 696 80			3 gang horizontal with cable gland
0 695 96	0 696 46		membrane cable gland
0 695 99			membrane cable gland 2 entries
0 695 98			set of 4 covers
0 696 52			1 gang with screw gland gaz pitch (1 at the top)
0 696 64			2 gang vertical with screw gland gaz pitch (2 at the top )
0 696 74			2 gang horizontal with screw gland gaz pitch (2 at the top)
0 696 53			screw gland gaz pitch
0 696 56			1 gang with screw gland ISO 20 (1 at the top)
0 696 57			1 gang with screw gland ISO 20 (1 at the top 1 at the bottom )
0 696 58			1 gang with screw gland ISO 20 (2 at the top)
0 696 59			1 gang with screw gland ISO 20 (2 at the top – 1 at the bottom)
0 696 66			2 gang vertical with screw gland ISO 20 (1 at the top)
0 696 67			2 gang vertical with screw gland ISO 20 (1 at the top 1 at the bottom )
0 696 68			2 gang vertical with screw gland ISO 20 (2 at the top)
0 696 69			2 gang vertical with screw gland ISO 20 (2 at the top – 1 at the bottom)
0 696 78			2 gang horizontal with screw gland ISO 20 (2 at the top)
0 980 03			screw gland ISO 20
0 695 79			Mosaic adaptor with lockable smoked lid
0 695 80		0 707 25	Mosaic adaptor with smoked lid
0 695 84	0 696 84		Mosaic adaptor with lid
0 695 82			Mosaic adaptor without lid



LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)



Signature: **Julien Gauthier**  
Certification Officer

Date: 07/06/2021