


IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS ELECTRIQUES
(IECEE) METHODE OC

CB TEST CERTIFICATE

CERTIFICAT D'ESSAI OC

Product
Produit

Double socket-outlet with pin-type earthing contact

Name and address of the applicant
Nom et adresse du demandeurLegrand Magyarország Villamossági Rendszerek Zrt.
Ipartelepí út 14.
H-6600 Szentes, HungaryName and address of the manufacturer
Nom et adresse du fabricantLegrand France
128, Avenue du Maréchal de Lattre de Tassigny
FR-87045 Limoges, FranceName and address of the factory
Nom et adresse de l'usineEMB Electrical Industries S.A.E.
Second Industrial Zone,
12659 Sadat (province: Menofia), EgyptNote: When more than one factory, please report on page 2
Note: Lorsque il y plus d'une usine, veuillez utiliser la 2^{ème} pageRatings and principal characteristics
Valeurs nominales et caractéristiques principales250V~, 16A;
Standards Sheet: IEC 60083:1975 St. Sh. C3a and
Figure 1 and 2 of standard PN-E-93201:1997;
with earthing contact; rewirable
(see Test Report for further ratings)Trademark (if any)
Marque de fabrique (si elle existe)Type of Manufacturer's Testing Laboratories used
Type de programme du laboratoire d'essais
constructeur

Model / Type Ref.
Ref. De typeNSFGP /design: "Niloé"/
(See page 2 of this Certificate for further details)Additional information (if necessary may also be
reported on page 2)
Les informations complémentaires (si nécessaire,
peuvent être indiqués sur la 2^{ème} page

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

IEC 60884-1:2002 + AMD1:2006 + AMD2:2013

As shown in the Test Report Ref. No. which forms part
of this Certificate

28234980 001

Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce CertificatThis CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme National de Certification

Type variants and reference numbers:

Type and description	Reference numbers	
	white	ivory
2x2P+E socket outlet with screw-type terminals and with shutters, type NSFPG	764542 396438*	764642 396439*

* Reference numbers of socket-outlet which deliver with unique packaging (DIY).
Remark: Reference numbers in the same cell are technically identical.

Accessories:

Plates: 665001 (white),
665011 (ivory)

Additional information (if necessary)
Information complémentaire (si nécessaire)



Date: 2016-10-12

TÜV Rheinland InterCert Kft., Division ME
H-1132 Budapest, Váci út 48/A-B
www.tuv.hu

Signature:

Gabor Kassai
Gabor Kassai

