

IEC

IECEE

Ref. Certif. No.

FR\_715099

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Box for suspension means  
Enclosure for electrical installations

Name and address of the applicant

LEGRAND FRANCE  
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY  
87045 LIMOGES CEDEX  
FRANCE

Name and address of the manufacturer

LEGRAND FRANCE  
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY  
87045 LIMOGES CEDEX  
FRANCE

Name and address of the factory

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

Series PLEXO : See Annex

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC 665305 dated 07/04/2015. Update further to the evolution of the standard(s) / addition and suppression of references

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60670-1:2015  
IEC 60670-22:2003 + A1:2015


As shown in the Test Report Ref. No. which forms part of this Certificate

13055676-773861 Version 01

This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
33 avenue du Général Leclerc  
92260 Fontenay-aux-Roses, FRANCE  
[www.lcie.fr](http://www.lcie.fr)



Signature: Julien GAUTHIER  
Certification Officer

Date: 11/07/2022

## ANNEX

**Name and address of the factories:****PLAST'AVENIR 87**

3 rue Sismondi  
87000 LIMOGES  
FRANCE

**LEGRAND FRANCE**

128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY  
87045 LIMOGES CEDEX  
FRANCE



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
33 avenue du Général Leclerc  
92260 Fontenay-aux-Roses, FRANCE  
[www.lcie.fr](http://www.lcie.fr)

Date: 11/07/2022



LABORATOIRE CENTRAL DES  
INDUSTRIES ELECTRIQUES  
S.A.S au capital de 15.745.984 €  
RCS Nanterre B 488 363 174  
33 avenue du Général Leclerc  
F - 92266 FONTENAY AUX ROSES


Signature:  **Julien GAUTHIER**  
Certification Officer

Ref.	Hight (mm)	Dimension (mm)	Direct entry membrane gland	Know-out cable entry	Capacity of connexion (mm <sup>2</sup> )	Maximum number of wires	Color	Resistance to glow-wire test	Specificity
0 920 11	45	80 x 80		7	4	6 x 3	grey	650°C	Smooth faces
0 920 20	55	105 x 105		7	6	5 x 3	grey	650°C	
0 920 04	34	80 x 43		10	2,5	4 x 3	grey	650°C	With pre-cut knock-out cable entries
0 920 09	45	80 x 80		7	4	6 x 3	red-anthracite	960° C	
0 920 14	45	80 x 80		7	4	6 x 3	grey	650°C	
0 920 21	55	105 x 105		7	6	5 x 3	red-anthracite	960° C	
0 920 24	55	105 x 105		7	6	5 x 3	grey	650°C	
0 920 01	40	Φ 60	4 (Φ 20)		2,5	3 x 3	grey	650°C	With direct entry membrane glands
0 945 13	40	Φ 60	4 (Φ 20)		2,5	3 x 3	grey	650°C	
0 920 02	45	Φ 70	4 (Φ 20)		2,5	5 x 3	grey	650°C	
0 945 14	45	Φ 70	4 (Φ 20)		2,5	5 x 3	grey	650°C	
0 920 03	45	Φ 70	4 (Φ 20)		2,5	5 x 3	white	650°C	
0 945 15	45	Φ 70	4 (Φ 20)		2,5	5 x 3	white	650°C	
0 920 05	40	65 x 65	7 (Φ 20)		2,5	5 x 3	grey	650°C	
0 945 16	40	65 x 65	7 (Φ 20)		2,5	5 x 3	grey	650°C	
0 920 12	45	80 x 80	7 (Φ 20)		4	6 x 3	grey	650°C	
0 945 17	45	80 x 80	7 (Φ 20)		4	6 x 3	grey	650°C	
0 920 13	45	80 x 80	7 (Φ 20)		4	6 x 3	white	650°C	
0 945 18	45	80 x 80	7 (Φ 20)		4	6 x 3	white	650°C	
0 920 15	45	80 x 80	7 (Φ 20)		4	6 x 3	red-anthracite	960° C	
0 920 22	55	105 x 105	7 (Φ 25)		6	5 x 3	grey	650°C	
0 945 19	55	105 x 105	7 (Φ 25)		6	5 x 3	grey	650°C	
0 920 23	55	105 x 105	7 (Φ 25)		6	5 x 3	white	650°C	
0 945 20	55	105 x 105	7 (Φ 25)		6	5 x 3	white	650°C	
0 920 25	55	105 x 105	7 (Φ 25)		6	5 x 3	red-anthracite	960°C	



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
 33 avenue du Général Leclerc  
 92260 Fontenay-aux-Roses, FRANCE

[www.lcie.fr](http://www.lcie.fr)



Signature: **Julien GAUTHIER**  
 Certification Officer

Date: 11/07/2022

**Classification**

Rated insulation voltage
Nature of their material
Method of installation
Type of inlets (outlets)
Clamping means
Minimum and maximum temperatures during installation
Boxes and enclosures for hollow walls and the like
Method of fixing the terminals or connecting devices in the connecting box
Material box
Material lid
IK

**Accessories**


Designation	Reference	Dimension	Color
<b>Direct entry membrane glands</b>	0 919 14	Φ 20mm	grey
	0 919 08	Φ 20mm	white
	0 919 09	Φ 20mm	anthracite
	0 919 15	Φ 25mm	grey
	0 919 00	Φ 25mm	white
	0 919 01	Φ 25mm	anthracite
<b>Membrane glands</b>	0 919 10	Φ 25mm	grey
	0 919 11	Φ 25mm	grey
<b>Cable glands</b>	0 919 30	ISO 16	
	0 919 31	ISO 20	



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
 33 avenue du Général Leclerc  
 92260 Fontenay-aux-Roses, FRANCE

[www.lcie.fr](http://www.lcie.fr)

Date: 11/07/2022



Signature:  **Julien GAUTHIER**  
 Certification Officer