

UK DECLARATION OF CONFORMITY

We : MANUFACTURER
Schneider Electric Industries SAS
35 rue Joseph Monier
Rueil Malmaison 92500 – France

UK REPRESENTATIVE Schneider Electric Limited Stafford Park 5 Telford, TF3 3BL - United Kingdom

Hereby declare under our sole responsibility that the products:

Trademark	Schneider Electric Inc.	
Product, Type	PowerLogic AccuSine PCSN, Active filter	
List of reference and options	See next pages	

Are in conformity with the requirements of the following regulations, which was demonstrated by application the following designated standards.

Regulation	Designated standard / Notified body reference
Electrical Equipment (Safety) Regulations SI 2016 No. 1101	BS EN 62477-1:2012+A12:2021
The Electromagnetic Compatibility Regulations SI 2016 No. 1091	BS EN IEC 61000-6-2:2019 BS EN IEC 61000-6-4:2019
The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012 SI 2012 No. 3032	BS EN IEC 63000:2018

Subject to correct installation, maintenance and use conforming to its intended purpose, to the applicable regulations and standards, to the supplier's instructions and to accepted rules of the art.

This declaration becomes invalid in the case of any modification to the products not authorized by us.

Person in charge of the documentation (Manufacturer): Ruslan Drofyak

Schneider Electric USA Inc, 12345 SW Leveton Drive Tualatin OR 97062 United States

Issued at Telford - United Kingdom (Representative): Date & Signature 7-Oct-2021

Name : David WILLIAMS

VP Marketing UK&I

David Williams

Zone UK & Ireland



UK DECLARATION OF CONFORMITY



PowerLogic AccuSine PCSN Active Filter is a harmonic filter, displacement power factor correction and load balancing device

The Active Filters are designed for retrofit of current SWP applications and can be used in parallel for larger loads. It also provides easy communication to building management systems (BMS), and other systems.

Annex: Applied BS standards

Commercial name(s)	Commercial reference(s)	UKCA marking application date	Applicable standards
PowerLogic AccuSine PCSN	PCSN020Y4CH00 PCSN030Y4CH00 PCSN050Y4CH00 PCSN060Y4CH00 PCSN060Y4CH00E PCSN020Y4W20 PCSN050Y4W20 PCSN050Y4W20 PCSN060Y4W20 PCSN060Y4W20E PCSN060Y4R19 PCSN060Y4R19 PCSN060Y4R19 PCSN050Y4R1 PCSN050Y4N1 PCSN050Y4N1 PCSN050Y4N1 PCSN060Y4N1	2021	As active filter: EMC Directive BS EN IEC 61000-6-2:2019 BS EN IEC 61000-6-4:2019 LV directive BS EN 62477-1:2012+A12:2021