

# Certificate of Conformity

issued by Curtis-Straus

Company: APC Corporation  
Product Tested: NetBotz Room Sensor Model NBPD0155  
Testing Date: July 23 to August 5, 2008  
Report No.: EI0879-1

*A sample of the product as configured in the accompanying test report has been found to comply with the following standards:*

## EMC Emissions:

- EN 55022:1998/A1:2000/A2:2003 Class A ITE emissions requirements (EU, AS/NZS)
- ICES-003 Issue 4 Class A Digital Apparatus emissions requirements (Canada)
- FCC 47 CFR Part 15 Class A emissions requirements (USA)
- VCCI Class A ITE emissions requirements (Japan)
- EN 61000-3-2:2006 Limits for harmonic current emissions (equipment input current up to and including 16A per phase)
- EN 61000-3-3:2005 Limitation of voltage fluctuations and flicker in low-voltage supply systems for equipment with rated current up to and including 16 A

Registration numbers for all open area test sites can be found in the *Test Equipment Used* Section starting on page 45 of the attached report.

## EMC Immunity:

- EN 55024:1998/A1:2001/A2:2003 ITE - immunity characteristics: with the exception of EN 61000-4-5 AC surge

*Attested to by the hands and seals:*

For Curtis-Straus

For the Manufacturer or Importer

  
Test Engineer      08/27/08  
Date

  
EMC Manager      8/27/08  
Date