



# ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **43-227-04**

Valid from: 2022 12 17  
until: 2024 12 17

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company: **PC Electric Ges.m.b.H.**  
Diesseits 145  
4973 St. Martin im Innkreis  
Austria

Product: **Appliance inlets for industrial purposes**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **TGM-VA EE 35800**

**Österreichischer Verband für Elektrotechnik**  
Head of OVE Certification

*T. Neumayer*

Digitally signed by T. Neumayer  
Email=t.neumayer@ove.at

Dipl.-Ing. T. Neumayer

Wien, 2022 11 29



## OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.



**Manufacturer:**

PC Electric Ges.m.b.H.  
Diesseits 145  
4973 St. Martin im Innkreis  
Austria

**Factory location(s):**

PC Electric Ges.m.b.H.  
Diesseits 145  
4973 St. Martin im Innkreis  
Austria

**Tested and certified according to:**

ÖVE/ÖNORM EN 60309-1:2013-03-01  
ÖVE/ÖNORM EN 60309-2:2013-03-01

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

**Product: Appliance inlets for industrial purposes**

**Type designation:**

**Rating:**

**Trademark:**

**572**

Rated current: 32 A  
Insulation voltage: 50 V  
IP44 or IP44/IP54  
Wall mounted appliance-inlet  
without minor keyway

PCE / ELCEE / METECEE

**592**

Rated current: 32 A  
Insulation voltage: 50 V  
IP44 or IP44/IP54  
Wall mounted appliance-inlet  
with minor keyway

PCE / ELCEE / METECEE

**OVE Certification**

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

**573**

Rated current: 32 A  
Insolation voltage: 50 V  
IP44 or IP44/IP54  
Wall mounted appliance-inlet  
without minor keyway

PCE / ELCEE / METECEE

**593**

Rated current: 32 A  
Insolation voltage: 50 V  
IP44 or IP44/IP54  
Wall mounted appliance-inlet  
with minor keyway

PCE / ELCEE / METECEE

**672**

Rated current: 32 A  
Insolation voltage: 50 V  
IP44 or IP44/IP54  
Flanged appliance-inlet  
without minor keyway

PCE / ELCEE / METECEE

**692**

Rated current: 32 A  
Insolation voltage: 50 V  
IP44 or IP44/IP54  
Flanged appliance-inlet  
with minor keyway

PCE / ELCEE / METECEE

**673**

Rated current: 32 A  
Insolation voltage: 50 V  
IP44 or IP44/IP54  
Flanged appliance-inlet  
without minor keyway

PCE / ELCEE / METECEE

**693**

Rated current: 32 A  
Insolation voltage: 50 V  
IP44 or IP44/IP54  
Flanged appliance-inlet  
with minor keyway

PCE / ELCEE / METECEE

---

**OVE Certification**

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

## Typelist

Type	Poles	Position minor keyway [h]	Rated operating voltage V [V]	Frequency [Hz]	Minor keyway
<b>572</b>	<b>2</b>	-	20-25	50 und 60	without
<b>592</b>		12	40-50	50 und 60	with
		4	20-25 and 40-50	100-200	
		2		300	
		3		400	
		11		>400-500	
		10		DC	
<b>573</b>	<b>3</b>	-	20-25	50 und 60	without
<b>593</b>		12	40-50	50 und 60	with
		4	20-25 and 40-50	100-200	
		2		300	
		3		400	
		11		>400-500	
		10		DC	
<b>672</b>	<b>2</b>	-	20-25	50 und 60	without
<b>692</b>		12	40-50	50 und 60	with
		4	20-25 and 40-50	100-200	
		2		300	
		3		400	
		11		>400-500	
		10		DC	
<b>673</b>	<b>3</b>	-	20-25	50 und 60	without
<b>693</b>		12	40-50	50 und 60	with
		4	20-25 and 40-50	100-200	
		2		300	
		3		400	
		11		>400-500	
		10		DC	

### OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.